



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: Mukilteo

School Name: Olivia Park Elementary

School Code: 3121

School Address: 200 108th St Southwest, Everett Washington 98204

Number of Samples Collected: 62

Date Collected: 05/02/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
22384	other	other		<1	05/23/2019	6:02 AM, 02570
22385	FirstDraw	Bubbler	Commons Fountain	<1	05/23/2019	Near Cafeteria
22386	FirstDraw	Bubbler	Cafeteria	<1	05/23/2019	
22387	FirstDraw	Tap	Kitchen	17	05/23/2019	Left Sink Tap
22388	FirstDraw	Tap	Kitchen	15	05/23/2019	Right Sink Tap
22389	FirstDraw	Bubbler	In Hallway Near Room 27	1	05/23/2019	
22390	FirstDraw	Bubbler	Room 27	1	05/23/2019	
22391	FirstDraw	Tap	Room 27	2	05/23/2019	
22392	FirstDraw	Bubbler	Room 25	<1	05/23/2019	
22393	FirstDraw	Tap	Room 25	1	05/23/2019	
22394	FirstDraw	Bubbler	Room 26	<1	05/23/2019	
22395	FirstDraw	Tap	Room 26	3	05/23/2019	
22396	FirstDraw	Bubbler	Room 24	1	05/23/2019	
22397	FirstDraw	Tap	Room 24	2	05/23/2019	Mineral deposits on aerator
22398	FirstDraw	Bubbler	Room 23	1	05/23/2019	
22399	FirstDraw	Tap	Room 23	4	05/23/2019	
22400	FirstDraw	Bubbler	Room 22	1	05/23/2019	Some corrosion near spout
22401	FirstDraw	Tap	Room 22	3	05/23/2019	
22402	FirstDraw	Bubbler	Room 21	1	05/23/2019	
22403	FirstDraw	Tap	Room 21	2	05/23/2019	
22404	FirstDraw	Bubbler	Room 1	1	05/23/2019	
22405	FirstDraw	Tap	Room 1	1	05/23/2019	
22406	FirstDraw	Bubbler	Room 2	2	05/23/2019	
22407	FirstDraw	Tap	Room 2	2	05/23/2019	
22408	FirstDraw	Bubbler	Room 3	1	05/23/2019	
22409	FirstDraw	Tap	Room 3	2	05/23/2019	
22410	FirstDraw	Bubbler	Room 4	1	05/23/2019	
22411	FirstDraw	Tap	Room 4	1	05/23/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23412	FirstDraw	Bubbler	Room 6	1	05/23/2019	
23413	FirstDraw	Tap	Room 6	1	05/23/2019	
23414	FirstDraw	Bubbler	Room 5	1	05/24/2019	
23415	FirstDraw	Tap	Room 5	2	05/24/2019	
23416	FirstDraw	Bubbler	Room 8	1	05/24/2019	
23417	FirstDraw	Tap	Room 8	1	05/24/2019	
23418	FirstDraw	Bubbler	Room 7	1	05/24/2019	
23419	FirstDraw	Tap	Room 7	1	05/24/2019	
23420	FirstDraw	Bubbler	Room 11	4	05/24/2019	
23421	FirstDraw	Tap	Room 11	3	05/24/2019	
23422	FirstDraw	Bubbler	Room 12	2	05/24/2019	
23423	FirstDraw	Tap	Room 12	4	05/24/2019	
23424	FirstDraw	Bubbler	Room 10	<1	05/24/2019	
23425	FirstDraw	Tap	Room 10	5	05/24/2019	
23426	FirstDraw	Bubbler	Room 17	<1	05/24/2019	
23427	FirstDraw	Tap	Room 17	2	05/24/2019	
23428	FirstDraw	Bubbler	Room 18	1	05/24/2019	
23429	FirstDraw	Tap	Room 18	4	05/24/2019	
23430	FirstDraw	Bubbler	Room 20	1	05/24/2019	
23431	FirstDraw	Tap	Room 20	2	05/24/2019	
23432	FirstDraw	Bubbler	Room 19	1	05/24/2019	
23433	FirstDraw	Tap	Room 19	3	05/24/2019	
23434	FirstDraw	WaterCooler	Portable 35	<1	05/24/2019	
23435	FirstDraw	WaterCooler	Portable 34	<1	05/24/2019	
23437	FirstDraw	Bubbler	Room 16	2	05/24/2019	
23438	FirstDraw	Tap	Room 16	TB	NA	
23439	FirstDraw	Bubbler	Room 15	1	05/24/2019	
23440	FirstDraw	Tap	Room 15	1	05/24/2019	
23441	FirstDraw	Bubbler	Room 14	2	05/24/2019	Some mineral deposits near spout of bubbler
23442	FirstDraw	Tap	Room 14	2	05/24/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23443	FirstDraw	Bubbler	Room 13	1	05/24/2019	
23444	FirstDraw	Tap	Room 13	2	05/24/2019	
23445	FirstDraw	Bubbler	Health Clinic	4	05/24/2019	
23446	FirstDraw	Tap	Health Clinic	2	05/24/2019	Some mineral deposits under aerator